WOOD/COAL BURNING STOVE SUPPLEMENTAL INSPECTION FORM			Insured's Name			Policy No.	
Stove/Furnace Unit	Туре	Open Hearth (No doors)	☐ Pot Belly, B (Loose fittin			tting, draft-limiting doors and sean	ns)
	Construction	☐ Sheet Metal	☐ Cast Iron	☐ Brick Lined	Any Cracks or B	Broken Parts? ☐ Yes ☐ No	
	Fuel	□Wood	] Coal	Other (specify):			
	Principal Use	☐ Primary Heat Source (More than 50 days/yr.)		Supplemental Heating (Less than 50 days/yr.)		☐ Cooking	
	Installed By	☐ Owner ☐ Contractor		☐ Month/Year of Installation		on	
	Inspected By	☐ Building Inspector ☐ Fire Department ☐ Other (specify):					
Chimney/Chimney Connector (Stove Pipe)	Installation	Stove placed at least 36" from combustible well or furnishings, or 18" from non-combustible shield with 1" air space to combustible wall.		Non-combustible pad or surface below stove, extends at least 18" beyond loading door and 12" beyond side and rear.		Stove legs allow at least 4" air spelow stove.	pace
		☐ Yes [	☐ No	☐ Yes	□ No	☐ Yes ☐ No	
	Туре	☐ Masonry ☐ U.L. Listed Metal Chimney					
	Cleaned/ Inspected	When last cleaned (Mo./Yr.)		Last inspected (Mo./Yr.)		Are ashes disposed of in a fireproduction of the container? ☐ Yes ☐ No	roof
	Installation	Passes through non-combustible thimble collar or opening which is at least 12" larger in diameter than stove pipe:		Connector to chimney under 10' in length:		Galvanized steel pipe:	
Chi		☐ Yes ☐ No		☐ Yes ☐ No		☐ Yes ☐ No	
		More than two bonds:		Horizontal portion ris per linear ft. of pipe I chimney connection than stove end:	ength so	Pipe sections overlap to contain creosote flowback:	
		☐ Yes ☐	No	☐ Yes [	□ No	☐ Yes ☐ No	
Recomm- dations							

